

ORGANIC, NON-TOXIC, EARTH FRIENDLY HC BLEND

Ionel OPREA
"Dunărea de Jos" University of Galati

ABSTRACT

The paper presents the modeling of the single stage vapour compression refrigerating cycle with HC Refrigerant. The ecological refrigerant used: HC - 12a; the results - the exergetic efficiency and the coefficient of performance (COP) vs. superheating efficiency and the evaporating temperature - were obtained based on the computer program using the corresponding state equations for refrigerant.

REFERENCES

- [1] Aradau, D., Costiuc L., - Cercetarea instalatilor frigorifice cu comprimare mecanica de vaporii cu agenti ecologici. Grant CNSCU, nr.1154/1996;
- [2] Aradau, D. – L’analyse exergetique des installation frigorifique a un et deux etages de compression utilisant des compresseurs a piston – Buletinul Universitatii din Galati, Anul II, Fascicula IV, 1979, pp. 43-50.
- [3] Aradau, D., Costiuc L., - Optimisation of the Refrigeration Machinery Using R152a. International Conference of the B1, B2, E1, and E2 International Institute of Refrigeration Commissions, 1996, Bucuresti.
- [4] *** - ASHRAE Handbook, 1985 Fundamentals, SI Edition